



Declaration of Conformity for Smoke-Spill Motors

We CMG Pty. Ltd.
of 19 Corporate Avenue
Rowville
Victoria Australia 3178

ACN 005 118 114

declare that the product:

Product name Cage induction motor

Series SGAHS, HGAHS

Frame sizes 80 to 200

Ins. Class H

to which this declaration relates is in conformance with the following standard:

<i>Title</i>	<i>Number</i>	<i>Date of issue</i>
Methods of test and rating requirements for smoke-spill fans	AS 4429	1999

Rating 200°C for 120 minutes or
300°C for 30 minutes

Application Dual purpose

This declaration is supported by:

- *Component selection, Test Facility and Testing Procedure approved by an independent engineering consultant (Dr Peter I. Cooper).*
- *Tests carried out by CMG Technology to AS 4429 - 1999.*

Signed by


Jack Gringlas

Title

Managing Director

Date

26/04/2007